



**TOWN OF BLUFFTON  
DUCT SEALING CERTIFICATE**

Growth Management Customer Service Center  
20 Bridge Street  
Bluffton, SC 29910  
(843) 706-4500  
www.townofbluffton.sc.gov  
[applicationfeedback@townofbluffton.com](mailto:applicationfeedback@townofbluffton.com)

<b>Duct Sealing Certificate Due before Final Inspection</b>					
Permit Number:					
Contractor Name:			Owner Name:		
Address:			Address:		
Phone:			Phone:		
Location of Work:					
The duct tightness was tested by the above referenced contractor.					
<b>CFM25 per 100 ft<sup>2</sup> of Conditioned Floor Area = CFM25 x 100/Conditioned Floor Area Served</b>					
If all ducts are not located within conditioned space, builder must verify that either the post construction duct leakage to outdoors (PCO) is $\leq 8$ cfm/100 ft <sup>2</sup> , the post construction total duct leakage (PCT) is $\leq 12$ cfm/100 ft <sup>2</sup> . The Rough-In total leakage shall be $\leq 6$ cfm/100 ft <sup>2</sup> of conditioned floor area, if air handler is not installed at the time of test the total leakage shall be $\leq 4$ cfm/100 ft <sup>2</sup> of conditioned floor area. State which method was used to conduct the duct tightness test: duct blower (DB), modified blower door subtraction method (MBDS), or automated multipoint blower door (AMBD).					
Table					
System	Method (DB, MBDS, AMBD)	Test (PCO, PCT, RIT)	CFM25	Area Served (ft <sup>2</sup> )	Test Result
1					
2					
3					
Certification					
The Contractor hereby certifies the above referenced duct tightness test was done in accordance with the specification established by the 2009 International Energy Conservation Code Section 403.					
_____		_____		_____	
Print name		Signature of Mechanical Contr/authorized agent		Date	